



Tualatin Street and Highland Drive Storm Sewer and Pavement Rehabilitation

DATE: March 18, 2016

ADDENDUM NO. 1

Addition/Change to the Contract Documents

The work provided for in this addendum shall become a part of the drawings and specifications for this project.

1. Treated Subgrade, 10-Inches Thick (SW Tualatin Street Bid Item #14 and SW Highland Drive Bid Item #13) shall be tested by proof rolling in accordance with Section 00344.45(b) of the Oregon Standard Specifications for Construction, 2015. No geotechnical testing will be required for this bid item.

This ADDENDUM shall be signed and attached to the Bidder's Proposal and shall subsequently become part of the Contract Documents.

Company Name	
Contractor Name	
Contractor Signature	
Date	